



**TOWN OF DRACUT, MASSACHUSETTS
FIRE DEPARTMENT**

488 Pleasant Street

Office: (978) 454-2113

Fax: (978) 454-1443

Alison,

After having several conversations and meetings with the builder, Kevin O'Brien, over the past several months, he understands the Fire Department's requirements for this project. I have communicated to him those requirements and he is fully amenable to incorporating all of them. The requirements are that all of the buildings are to be fully sprinklered with an NFPA 13R system, fully alarmed with a residential fire alarm system in each unit, the fire alarm system will sound upon activation of the sprinkler system, fire hydrants to be located within 100ft of every fire department sprinkler connection, and that the site plan will accommodate access for the departments largest apparatus (a mid-mount Tower Ladder).

All these requirements have been addressed with Mr. O'Brien and will be incorporated into the plans to be submitted once the project is approved and progresses into the construction phase. The Fire Department has no additional comments or concerns to put forward at this time.

Sincerely,

A handwritten signature in black ink. The signature appears to read "Tom Mackey" in a cursive, flowing script.

Thomas Mackey
Deputy Chief, Operations
Fire Prevention Officer
Dracut Fire Department
978-454-1526 x3014

The Town of Dracut is an Equal Opportunity/Affirmative Action Employer